





ANCHOR NOTE: FIRST (BOTTOM) ANCHOR STARTING AT NO MORE THAN HALF OF THE MAXIMUM ON-CENTER DISTANCE. HIGHEST ANCHOR INSTALLED AT LEAST AS HIGH AS THE DOOR OPENING.



THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS IS THE RESPONSIBILITY OF THE BUILDING ENGINEER OR ARCHITECT OF RECORD.

NOTICE: Confidential/Proprietary information of CLOPAY BUILDING PRODUCTS CO. is contained herein and may not be disclosed, used, duplicated, made available, or distributed without its prior consent. Failure to observe this notice may result in liability for any damages and losses resulting therefrom.

Third Angle Projection

Unless Stated Otherwise TOLERANCES are

.0 = ±.03

.00 = ±.015

.000 = ±.005

.0000 = ±.001

Degrees = ±1/2°

Unless Stated Otherwise DIMENSIONS ARE IN INCHES.

Glopay Building Products Company

8585 Duke Boulevard Mason, OH 45040
Tel. No. 1-513-381-4800
Fax No. 1-513-762-3519

DESCRIPTION: MODEL 3300W1 12' WIDE

DRAWN BY: DAS DATE: 5/27/03 SCALE: NTS DWG. B

CHECKED BY: SH DATE: 08/28/03 SHEET 1 OF 1 SIZE B

DWG. NO.: 102888 REV. NO. 00

MARK WESTERFIELD, P.E. FLORIDA P.E. #48495, NC P.E. #23832, TEXAS P.E. #91513

DESIGN LOADS: +13.5 PSF & -13.5 PSF
TEST LOADS: +20.0 PSF & -20.0 PSF

PART NO.: N/A